

# ECODESIGN TEST CERTIFICATE

Extract of report no.: 300-ELAB-2009

**Manufacturer:** CN MASKINFABRIK A/S  
Skovløkkevej 4, 6510 Gram  
CVR nr. 15101733

P nr. 1000860133

**Product:** Biofuel boiler



**DANISH  
TECHNOLOGICAL  
INSTITUTE**

Teknologiparken  
Kongsvang Allé 29  
DK-8000 Aarhus C  
Phone +45 72 20 10 00  
Fax +45 72 20 10 19  
Info@teknologisk.dk

**Model:** CN15 Unit

**Procedure:** Testing according to EN 303-5:2012

**Requirements:**

**Stoking princ.:** Automatic **Fuel:** Biomass

Testing has been carried out with wood pellets (C1) with the following results:

## TEST RESULTS

Measurement	Unit	Result	Limits
Nominal heat output	kW	15.5	
CO at 10% O <sub>2</sub>	mg/m <sub>n</sub> <sup>3</sup>	231	
OGC at 10% O <sub>2</sub>	mg/m <sub>n</sub> <sup>3</sup>	< 6	
Dust at 10% O <sub>2</sub>	mg/m <sub>n</sub> <sup>3</sup>	31	
NO <sub>x</sub> at 10% O <sub>2</sub>	mg/m <sub>n</sub> <sup>3</sup>	151	
Efficiency	%	94.1	
Minimum heat output	kW	4.2	
CO at 10% O <sub>2</sub>	mg/m <sub>n</sub> <sup>3</sup>	75	
OGC at 10% O <sub>2</sub>	mg/m <sub>n</sub> <sup>3</sup>	< 6	
Dust at 10% O <sub>2</sub>	mg/m <sub>n</sub> <sup>3</sup>	18	
NO <sub>x</sub> at 10% O <sub>2</sub>	mg/m <sub>n</sub> <sup>3</sup>	121	
Efficiency	%	90.8	
Seasonal emissions			
CO at 10% O <sub>2</sub>	mg/m <sub>n</sub> <sup>3</sup>	99	500
OGC at 10% O <sub>2</sub>	mg/m <sub>n</sub> <sup>3</sup>	< 6	20
Dust at 10% O <sub>2</sub>	mg/m <sub>n</sub> <sup>3</sup>	20	40
NO <sub>x</sub> at 10% O <sub>2</sub>	mg/m <sub>n</sub> <sup>3</sup>	125	200
Seasonal space heating energy efficiency			
η <sub>s</sub>	%	79	75
η <sub>son</sub>	%	84.6	
F1	%	3.0	
F2	%	2.9	

Aarhus, 30. November 2021

Anders Pødenphant  
B. Sc.